

## Open your mind. LUT. Lappeenranta University of Technology

# SCENARIOS FOR A SUSTAINABLE ENERGY SYSTEM IN THE ÅLAND ISLANDS IN 2030

**Results of EnergyPLAN modelling** 



Michael Child, Alexander Nordling & Christian Breyer First Results for Åland Smart Energy Platform Stakeholders September 5, 2016



- Introduction to study
- Main results and interpretation
- Questions and discussion






- Relatively compact geographic locations with homogeneous populations
- Components of the energy system tend to be less complex and are more easily documented than larger continental systems
- Generally associated with significant imports of expensive fossil fuels from or power interconnections with larger continental energy suppliers
- Eliminating dependency on imported energy carriers through expanded use of domestic renewable resources and storage solutions has been suggested as an alternative for islands around the globe
- Islands may also offer potential blueprints for energy system transitions towards sustainability that will occur on a larger scale with larger continental systems
- Island energy systems may encounter shares of RE beyond 50% much sooner in the future than mainland grids
- An attractive new business field for technology providers and start-ups which can serve as showcases



## Åland Islands




- 6,757 islands with a population of 28,983
- 60 islands are inhabited and connected by road or ferry
- Åland Smart Energy Platform began as a consortium of local stakeholders, international energy companies, technology providers and research institutes
- Goal is to envision and demonstrate how an energy system could enable the delivery of reliable, affordable, quality energy services which are free of fossil fuels to local end users




#### Open your mind. LUT. Lappeenranta University of Technolog:

### **Current situation (2014)**

- Total electricity supply 288.4 GWhe
  - − Oil 11.7 GWhe
  - Biomass 1 GWhe
  - Wind 57.4 GWhe
  - From Sweden 200.7 GWhe
  - From Finland 17.6 GWhe
- Total heat supply 115 GWhth
  - Oil 15 GWhth
  - Biomass 100 GWhth
- Transport demand 227 GWhth
  - Gasoline 129 GWhth
  - Diesel 98 GWhth



Electricity supply 2014 [GWh] – Total 288 GWh




Import Sweden = Import Finland = Oil

Wind power Bio power



Source: Statistics and Research Åland, "Statistical Yearbook of Åland 2015," 2015. Available: http://www.asub.ax/files/statistisk\_arsbok\_for\_aland\_2015.pdf.

#### Flows of energy - 2014






Open your mind. LUT. Lappeenranta University of Te

Scenarios for a sustainable energy system in the Åland Islands in 2030 Michael Child▶ Michael.Child@lut.fi

### Solar PV potential



November December Annual average



\* Yearly sum of global irradiation incident on optimally-inclined south-oriented photovoltaic modules

\*\*Yearly sum of solar electricity generated by optimally-inclined 1kWp system with a performance ratio of 0.75

© European Union, 2012 PVGIS http://re.jrc.ec.europa.eu/pvgis/

Authors: Thomas Huld, Irene Pinedo-Pascua EC · Joint Research Centre In collaboration with: CM SAF, www.cmsaf.eu

Legal notice. Neither the European Commission nor any person acting on behalf of the Commission is researchile for the user which much be made of this publication.

(85% performance ratio) Potential for 6989 MW<sub>p</sub> ground


Potential for 28 MW<sub>p</sub> rooftop  $\succ$ 



Scenarios for a sustainable energy system in the Åland Islands in 2030 Michael Child ► Michael.Child@lut.fi

### Wind power expansion projects and potential





#### Långnabba project

- Plan for 16 turbines, ~50 MW
- Total onshore potential could be 522 MW

#### Project Östra skärgården

- Planned to consist of 35-45 turbines of 3 MW, total ~100 MW.
- Connection to the new sea cable via station on Sottunga.
- Total offshore potential could be 4700 MW





Approximately 300 GWhth potential from biomass

- > 32,584 tonnes of municipal solid waste (MSW) potential
  - Equivalent to 181 GWhth
  - Shipped to Sweden for waste-to-energy (WTE) conversion
  - > Domestic WTE deemed not profitable
  - Perhaps 36 GWhe of electricity that comes from Sweden could be classified as Åland domestic resource?



#### **Primary aims – Research questions**

- Can a 100% sustainable energy system be achieved by 2030 for Åland?
- What is the least cost scenario that can result in a fully functional, reliable, 100% sustainable energy system for Åland in 2030?
- What are the roles of Power-to-Gas, Vehicle-to-Grid and other energy storage solutions in future energy system for Åland?
- To what extent can intermittent renewable energy production (solar PV and wind) play a part in the future energy system?
- What would be the optimal roles of domestic production of energy carriers and imports?
- > To what extent can the transport sector be electrified?



#### Methods – Scenario design




		Po	wer	Heat		Transport	
Scenario name	Scenario shortform	100 % Domestic	High trade	High HP usage	Biofuel import	Domestic production of sustainable fuels	Electrification of cars
2014	2014		X				0 %
2020 - Transition	2020		X		X		10 %
	2020		Α		Λ		10 /0
2030 - 100% Sustainable domestic focus							
Domestic production of sustainable fuels	2030 SDF Syn	X		X		X	50 %
Imported biofuels	2030 SDF Bio	X		X	X		50 %
2030 - 100% Sustainable trade	2030 ST			X	X		50 %
2020 1000/ C 4 1 11 . 4 4	2020 CNIE		V	v	V		<b>50</b> 0/
2030 - 100% Sustainable net export	2030 SNE		X	X	X		50 %
2030 - 100% Sustainable mobility							
Domestic production of sustainable fuels	2030 SM Syn			X		X	50 %
High Electrification	2030 SM El			X		X	100 %
2030 - BAU	2030 BAU		X		X		30 %



Scenarios for a sustainable energy system in the Åland Islands in 2030 Michael Child▶ Michael.Child@lut.fi

### EnergyPLAN





- Developed in 1999 at Aalborg University in Denmark
- Widely used and respected
- Energy system analysis carried out in hourly steps for one year
- Model includes analysis of electricity, heating and transport sectors
- Results form basis of technical regulation and market optimization strategies
- Main aim is to assist in the design of national energy planning strategies
- Model can also be applied on larger and smaller scales
- Free download from <u>http://www.energyplan.eu/</u>



### Main cost parameters for the year 2030



Technology	Capex [€/kW]	Opex fix [% of capex]	Opex var [€/kWh]	Lifetime [a]
Wind onshore	1000	2.5	0	25
Wind offshore	2100	3.4	0	25
PV ground mounted	550	1	0	35
PV rooftop	700	1	0	35
Biomass gasification	320	7	0	25
Biodiesel plant	2530	3	0	20
PtG plant (electrolysis and methanation)	600	3	0	15
Condensing power plant	980	3.16	2.636	27
CHP plant	1200	3.75	2.7	25
CHP boiler	800	3.7	0.15	29
CHP heat pump	3250	2	0.27	25
Interconnection	1200	1	0	40
	Capex	Opex fix	Opex var	Lifetime
	[€/kWh]	[% of capex]	[€/kWh]	[a]
Thermal storage	3	0.7	0	20
Gas storage	0.08	1	0	50

A more extensive list of cost assumptions is provided at the end of this presentation

#### **RES** capacity parameters for all scenarios



		Scenario									
				2030	2030	203	203	2030	2030		
			202	SDF	SDF	0	0	SM	SM	2030	
RES Capacities	Units	2014	0	Syn	Bio	ST	SNE	Syn	El	BAU	
Wind onshore	MW <sub>e</sub>	22.2	70	70	70	70	70	70	70	70	
Wind offshore	MW <sub>e</sub>	0	0	100	80	40	100	100	55	0	
Solar PV - Rooftop	MW <sub>e</sub>	0	10	28	28	28	28	28	28	15	
Solar PV - Ground mounted	MW <sub>e</sub>	0	0	55	50	50	50	50	55	0	




# Thermal power plant capacity and efficiency for all scenarios



			Scenario										
Thermal plant				2030	2030			2030	2030		Conversion		
capacities and				SDF	SDF	2030	2030	SM	SM	2030	efficiencies		
efficiencies	Units	2014	2020	Syn	Bio	ST	SNE	Syn	El	BAU	(%)		
Condensing PP	MW <sub>e</sub>	30	0	27	29	10	10	10	10	0	45%		
СНР	MWe	26.6	10	40	40	20	20	20	20	20	40% <sub>e</sub> , 50% <sub>th</sub>		
DH Boilers	MW <sub>th</sub>	30.8	18	14	13	15	18	13.5	15.3	20	90%		
DH Heat pumps	MW <sub>e</sub>	0	1	5	5	5	5	5	5	0	300%		







Open your mind. LUT. Lappeenranta University of Te




- Introduction to study
- Main results and interpretation
- Questions and discussion



### **Annual fuel consumption**








#### **Installed capacities**






Key insights:

- Solar PV includes 28 MW<sub>p</sub> rooftop in all 2030 scenarios, except BAU (15 MW<sub>p</sub>)
- In some scenarios, high installed capacities of wind power resulted in need for more thermal PP capacity



#### **Electricity production**






Key insights:

- Import and export of electricity kept low in most scenarios by design
- Export considered as curtailment in most 2030 scenarios
- 2030 SNE and BAU scenarios were exceptions



#### **Electricity consumption**






Key insights:

- Strong roles for electrified heating and transport
- High demands for methane in some scenarios (Syn) due to need for synthetic transport fuels



#### **Annualized costs**






Key insights:

- Higher annualized domestic investment costs in all 2030 scenarios
- > 2030 SM El has lowest cost (225 M€/a)
- Followed closely by 2030 ST (226 M€/a)
- > Range 225-247 M€/a


Total annualized costs of operating the energy system for each scenario including the costs of vehicles and watercraft batteries.



#### **Annualized costs**



Total annualized costs of operating the energy system for each scenario excluding the costs of vehicles, but including the costs of electric vehicle and watercraft batteries.



Open your mind. LUT. Lappeenranta University of Te

CARBON

ENERGY


Total annualized costs of operating the energy system for each scenario excluding vehicles and all electric vehicle and watercraft batteries.


#### Important question: What costs should be included in an analysis of the energy system?

Not including vehicle and battery costs might be preferable due to the fact that other end use devices (e.g. computers, washing machines, tanks) are not included NEO



### Hourly results: April 21-27 for 2030 SDF Syn






#### Key insights:


- Low RE production at start of week
- CHP production and V2G provide balance
- Solar PV production high all week
- Daily cycles of charging and discharging of V2G
- Multi-day cycle also noticeable
- V2G batteries fill towards end of week



Open your mind. LUT. Lappeenranta University of Te

#### Hourly results: November 19-25 for 2030 SDF Syn





#### Key insights:

- Low RE production at end of week
- Most challenging week of year for system
- CHP production and V2G provide balance
- Solar PV production low all week
- High winds at start of week
- Full V2G batteries empty over 3 days

System components work as expected to provide stability NEO



CARBON

Open your mind. LUT. Lappeenranta U

Scenarios for a sustainable energy system in the Åland Islands in 2030 Michael Child ► Michael.Child@lut.fi

#### Summary of storage discharge



Parameter	Unit	2030 SDF Syn	2030 SDF Bio	2030 ST	2030 SNE	2030 SM Syn	2030 SM EI
Electricity consumption	GWhe	422	422	422	422	422	452
Heat consumption	GWh <sub>th</sub>	375	375	375	375	375	375
Total energy consumption	GWh	797	797	797	797	797	827
V2G discharge	GWh <sub>e</sub>	99	85	66	104	97	78
Electricity from stored gas	GWh	3	25	0	0	0	0
Heat from stored gas	GWh <sub>th</sub>	0	25	0	0	0	0
DH storage discharge	GWh <sub>th</sub>	11	13	7	7	6	7
PV & wind directly consumed	GWh <sub>e</sub>	288	281	261	298	288	273
as % of PV & wind production		53 %	58 %	72 %	51 %	53 %	67 %
as % of all electricity production		45 %	48 %	55 %	47 %	45 %	53 %
as % of electricity consumption		68 %	67 %	62 %	71 %	68 %	60 %
PV & wind to electric storage	GWh <sub>e</sub>	238	182	74	112	245	115
as % of PV & wind production		44 %	38 %	20 %	19 %	45 %	28 %
PV & wind to curtailment	GWh <sub>e</sub>	22	23	28	171	15	20
as % of PV & wind production		4 %	5 %	0 %	0 %	3 %	5 %
Total storage discharge	GWh	113	147	73	111	103	85
as % of total consumption		14 %	18 %	9 %	14 %	13 %	10 %
Electricity storage discharge	GWh <sub>e</sub>	102	109	66	104	97	78
as % of electricity consumption		24 %	26 %	16 %	25 %	23 %	17 %
V2G discharge	GWh <sub>e</sub>	99	85	66	104	97	78
as % of electric storage discharge		97 %	78 %	100 %	100 %	100 %	100 %
Thermal storage discharge	GWh <sub>th</sub>	11	37	7	7	6	7
as % of heat consumption		3 %	10 %	2 %	2 %	2 %	2 %
Gas storage discharge	GWh <sub>gas</sub>	43	60	0	0	35	4
as % of grid gas consumption	940	34 %	87 %	0 %	0 %	29 %	

Scenarios for a sustainable energy system in the Åland Islands in 2030 Michael Child▶ Michael.Child@lut.fi




### Key observations I



- Kiviluoma (2013) found that the marginal benefits of higher penetration of plug-in hybrid electric vehicles decreased with higher participation in V2G services due to limited demands for power system reserves and system flexibility
- > However, closer analysis of these results reveals something different
- In the 2030 SM El scenario, the amount of intermittent RE being used directly is much higher (67% of PV and wind generation) compared to the 2030 SM Syn scenario (53%)
- Likewise, the discharge of electricity from V2G connections to the grid is much lower (17% of electricity consumption compared to 23%, respectively)
- In both scenarios the charging of V2G batteries is similar (139 GWh<sub>e</sub> and 138 GWh<sub>e</sub> for the 2030 SM EI and Syn scenarios, respectively)
- However, the former scenario sees a much higher (51 GWh<sub>e</sub> vs 30 GWh<sub>e</sub>) consumption of stored electricity by the larger number of vehicles and watercraft
- The key point is that stored electricity need not only be considered as storage for future use by the grid, but V2G batteries can provide a buffer between generation of intermittent RE and its use by end-users
  - > Also many other possibilities to use this energy Nissan already using the term V2X
- > Direct consumption of intermittent renewable energy reduces the need for storage and generation capacities
- In comparing the 2030 SM scenarios, it can be observed that the higher participation in V2G (2750 vs 1200 GWh<sub>e</sub>) for the EI and Syn scenarios, respectively, results in less need for gas storage (1.2 vs 9 GWh<sub>th</sub>), electrolyser capacity (6.1 vs 57.5 MW<sub>e</sub>), methanation capacity (3.9 vs 36.5 MWh<sub>gas</sub>) and offshore wind power capacity (55 MW<sub>e</sub> vs 100 MW<sub>e</sub>)
- As a result, total annualised costs were lower (225 M€/a vs 239 M€/a)



#### Flows of energy - 2014






Open your mind. LUT. Lappeenranta University of Te

Scenarios for a sustainable energy system in the Åland Islands in 2030 Michael Child► Michael.Child@lut.fi

#### **Annual energy flows**



2030 SM Syn






Recarbonised Finnish Energy System Michael Child ► Michael.Child@lut.fi

#### **Annual energy flows**



2030 SM EI





Recarbonised Finnish Energy System Michael Child ► Michael.Child@lut.fi

#### Levelised cost of electricity – 2030 SM El

2030 SM EI	Units	Wind - onshore	Wind - offshore	Solar PV ground mounted	Solar PV rooftop	Condensing plants	CHP plants
Сарех	€/kW <sub>e</sub>	1000	2100	550	700	980	1200
Opex_fixed	% of capex	2.50 %	3.40 %	1 %	1 %	3.16 %	3.75 %
Opex_var	€/MWh <sub>e</sub>	0	0	0	0	2.7	2.7
Fuel	€/MWh <sub>e</sub>	0	0	0	0	28.8	28.8
Efficiency	%	100%	100%	100%	100%	45%	90%
Lifetime	Years	25	25	35	35	27	25
Full load hours	Hours	2815	3163	1067	1067	1047	2368
WACC	%	7 %	7 %	7 %	7 %	7 %	7 %
crf	%/year	8.58 %	8.58 %	7.72 %	7.72 %	8.34 %	8.58 %
LCOE	€ cents/kWh <sub>e</sub>	3.9	8.0	4.5	5.7	17.4	9.7



Scenarios for a sustainable energy system in the Åland Islands in 2030 Michael Child▶ Michael.Child@lut.fi

#### Job creation



Parameter	Unit	2030 SDF Syn	2030 SDF Bio	2030 ST	2030 SNE	2030 SM Syn	2030 SM El	2030 BAU
Wind onshore	Job-years	602	602	602	602	602	602	602
Wind offshore	Job-years	1810	1448	724	1810	1810	996	0
Solar PV	Job-years	1486	1396	1396	1396	1396	1486	269
MCI Total	Job-years	3898	3446	2722	3808	3808	3083	871
Wind onshore	Jobs over 25 years	14	14	14	14	14	14	14
Wind offshore	Jobs over 25 years	20	16	8	20	20	11	0
Solar PV	Jobs over 35 years	25	23	23	23	23	25	5
O&M Total	Jobs over lifetimes	59	53	45	57	57	50	19
O&M Total	Job-years	1722	1569	1369	1669	1669	1497	508
Total	Job-years	5619	5015	4091	5477	5477	4580	1378

MCI- Manufacturing, Construction and Installation O&M – Operations and Maintenance

Not included: More jobs related to PtG, V2G, plant decommissioning



### Key observations II

- > A reliable energy system based on high sustainability criteria seems technically feasible for Åland in 2030
- The 2030 SM El scenario, with high levels of electrification of the transport sector, has emerged as the least cost solution
  - The 2030 SM El scenario provides a great deal of uniqueness and opportunity to explore and demonstrate products and services that have so far not been demonstrated with energy system scenario modelling
    - > Expanded role of V2G connections to marine watercraft
    - > This will require strong role of ICT services to aggregate participants and control loads
    - > Use of advanced smart-grid technology to manage distributed generation
    - > More strategic use of interconnections flexible energy system supported by flexible market
    - > Development of solutions in Åland can be scalable for continental systems
- > The role of energy storage solutions appears significant in each of the future scenarios
  - High shares of variable RE are not a difficulty in a well-planned system
  - On a seasonal basis, PtG technology can bridge the gaps between demand and supply at times when generation is most intermittent, but not necessary in all scenarios
  - > V2G connections balance supply and demand on a daily and multi-day basis
    - V2G batteries have a tendancy to be filled and not emptied
    - Correlation between V2G charging and variable RE generation
    - > Less need for seasonal storage (PtG) and offshore wind capacity
    - Further possibilities for V2X should be explored
  - In some scenarios storage is replaced by dependence on imports (electricity and biofuels)
- New job creation related to renewable energy production on Åland could total between at least 3100 and 3900 MCI job-years and 45-59 permanent O&M jobs, depending on the scenario
  - > These can be seen as a lower limit due to unaccounted MCI and O&M jobs anticipated for PtG and V2G



#### Conclusions



- > A fully sustainable energy system for Åland can be achieved by 2030
- Expanded roles of solar PV and wind power generation capacities through domestic investment can effectively replace reliance on imported energy carriers, promote sustainable growth, and eliminate the need for fossil fuels in the energy system
- The role of V2G connections and other energy storage solutions increase the flexibility of the energy system required when levels of variable renewable energy generation are high
- Expanding participation in V2G services to include more road vehicles and other vehicle types, such as boats, can result in less need for other energy storage solutions and reduced offshore wind power generation capacity, resulting in lower annualised costs
- V2G connections serve a strong role in accepting energy produced by solar PV and wind power generation in times of excess, and a much less noticeable role as a provider of electricity back to the grid
- The movement towards sustainability for Åland can result in several potential benefits outside of the boundaries of the energy system, such as promotion of employment, tourism and international partnerships
- > There are many pathways towards achieving 100% sustainable energy futures for Åland
- Perhaps the most urgent matter for the Åland Smart Energy Platform is to inform a wide range of actors and stakeholders of the possible options, and invite feedback
- The best option will be the one that the people of Åland choose for themselves through informed discourse





- Introduction to study
- Main results and interpretation
- Questions and discussion



### **Questions or comments?**













NEO-CARBON Energy project is one of the Tekes strategy research openings and the project is carried out in cooperation with Technical Research Centre of Finland VTT Ltd, Lappeenranta University of Technology (LUT) and University of Turku, Finland Futures Research Centre.

# FURTHER INFORMATION



### Main demand parameters



			Scenario								
Demands		Units	2014	2020	2030 SDF Syn	2030 SDF Bio	2030 ST	2030 SNE	2030 SM Syn	2030 SM EI	2030 BAU
Electricity		GWh <sub>e</sub>	288.5	342.83	422.23	421.94	421.94	421.94	422.11	451.54	405.54
District heating		GWh <sub>th</sub>	100.9	117	135	135	135	135	135	135	126
Individual heating	ı total	GWh <sub>th</sub>	265.53	253.03	240.05	240.05	240.05	240.05	240.05	240.05	249.05
Oil		GWh <sub>th</sub>	176.8	88.4	0	0	0	0	0	0	88.4
Biom	nass	GWh <sub>th</sub>	16	42.63	50.05	50.05	50.05	50.05	50.05	50.05	40.65
Heat	t pump	GWh <sub>th</sub>	30	82	150	150	150	150	150	150	80
Elect	tricity	GWh <sub>th</sub>	42.73	40	40	40	40	40	40	40	40
Fuel for transport	total	M km	340	360	415	415	415	415	415	415	415
Diese	el	GWh <sub>th</sub>	97.6	84	0	0	0	0	0	0	55.3
Biod	liesel	GWh <sub>th</sub>	0	0	40	0	0	0	40	30.73	0
Synt	hetic diesel	GWh <sub>th</sub>	0	0	29.2	0	0	0	29.2	9.27	0
Impo	orted biodiesel	GWh <sub>th</sub>	0	24	0	69.2	69.2	69.2	0	0	41.5
Petro	ol	GWh <sub>th</sub>	128.8	84	0	0	0	0	0	0	55.3
Synt	hetic petrol	GWh <sub>th</sub>	0	0	69.2	0	0	0	69.2	0	0
Impo	orted biopetrol	GWh <sub>th</sub>	0	24	0	69.2	69.2	69.2	0	0	41.5
Elect	tricity (Dump charge)	GWh <sub>e</sub>	0	7.2	10.3	10.3	10.3	10.3	10.3	17.8	25
Elect	tricity (Smart charge)	GWh <sub>e</sub>	0	0	31.1	31.1	31.1	31.1	31.1	51.2	0




NEO

CARBON ENERGY

# **Built environment (2014)**







Recarbonised Finnish Energy System Michael Child ► Michael.Child@lut.fi

### **Housing parameters**



				Scenario							
		Units	2014	2020	2030 SDF Syn	2030 SDF Bio	2030 ST	2030 SNE	2030 SM Syn	2030 SM EI	2030 BAU
Buildings		Thousands	13.325	13.9	14.5	14.5	14.5	14.5	14.5	14.5	14.5
Residential he	eating total	Thousands	10.272	10.716	11.292	11.292	11.292	11.292	11.292	11.292	11.292
0	Dil	Thousands	3.798	1.787	0	0	0	0	0	0	1.955
В	Biomass	Thousands	1.516	3.472	3.9	3.9	3.9	3.9	3.9	3.9	3.485
н	leat pump	Thousands	1.164	1.626	3.1	3.1	3.1	3.1	3.1	3.1	1.794
E	lectricity	Thousands	3.122	3.13	3.374	3.374	3.374	3.374	3.374	3.374	3.196
D	ЭН	Thousands	0.672	0.7	0.918	0.918	0.918	0.918	0.918	0.918	0.862
Other building	ıs total	Thousands	3.053	3.184	3.208	3.208	3.208	3.208	3.208	3.208	3.208
0	Dil	Thousands	0.666	0.463	0	0	0	0	0	0	0.345
В	Biomass	Thousands	0.394	0.442	0.7	0.7	0.7	0.7	0.7	0.7	0.615
Н	leat pump	Thousands	0.266	0.530	0.9	0.9	0.9	0.9	0.9	0.9	0.506
E	electricity	Thousands	1.499	1.5	1.326	1.326	1.326	1.326	1.326	1.326	1.504
D	Н	Thousands	0.228	0.25	0.282	0.282	0.282	0.282	0.282	0.282	0.238






		Scenario								
Vehicles	Units	2014	2020	2030 SDF Syn	2030 SDF Bio	2030 ST	2030 SNE	2030 SM Syn	2030 SM EI	2030 BAU
Number of cars/vans	Thousands	26.636	28	32	32	32	32	32	32	32
Vehicles that are EV	%	0	10%	50%	50%	50%	50%	50%	100%	30%
Dump charge	%	0	100%	25%	25%	25%	25%	25%	25%	100%
V2G connection	%	0	0	75%	75%	75%	75%	75%	75%	0
Number of buses/trucks	Thousands	0.841	0.9	1	1	1	1	1	1	1
Number of other vehicles	Thousands	7.625	8	9	9	9	9	9	9	9
V2G battery capacities (cars)	GWh	0	0	1.2	1.2	1.2	1.2	1.2	2.4	0
V2G battery capacities (boats)	GWh	0	0	0	0	0	0	0	0.35	0



### **Annualized investment costs**







# Breakdown of annalized investment costs



CARBON


**ENERGY** 

Annualized investment cost (M€)	2014	2020	2030 SDF	2030 SDF	2030 ST	2030	2030 SM	2030 SM	2030 BAU
			Syn	Bio		SNE	Syn	El	
Wind onshore	2.3	7.3	6.0	6.0	6.0	6.0	6.0	6.0	6.0
Wind offshore	0.0	0.0	18.0	14.4	7.2	18.0	18.0	9.9	0.0
PV - Rooftop	0.0	1.0	1.5	1.5	1.5	1.5	1.5	1.5	0.8
PV - Ground mounted	0.0	0.0	2.3	2.1	2.1	2.1	2.1	2.3	0.0
СНР	2.7	1.0	4.1	4.1	2.1	2.1	2.1	2.1	3.1
Cond. PP	3.1	0.0	2.2	2.4	0.8	0.8	0.8	0.8	0.0
Boilers	2.8	1.4	0.4	0.4	0.5	0.6	0.9	0.5	1.5
Heat pumps - DH	0.0	0.3	1.4	1.4	1.4	1.4	1.4	1.4	0.0
Heat storage	0.0	0.1	0.4	0.6	0.3	0.3	0.2	0.3	0.0
District heating grid	0.6	0.7	0.8	0.8	0.8	0.8	0.8	0.8	0.8
District heating substation	1.1	1.1	1.5	1.5	1.5	1.5	1.5	1.5	1.2
CO <sub>2</sub> Hydrogenation	0.0	0.0	2.3	1.5	0.0	0.0	2.4	0.3	0.0
Gas storage	0.0	0.0	0.1	0.1	0.0	0.0	0.1	0.0	0.0
Gas grid	0.0	0.0	3.9	3.9	0.0	0.0	0.0	0.0	0.0
Biofuel plants	0.0	0.0	1.8	0.0	0.0	0.0	1.8	1.4	0.0
Biomass gasification	0.0	0.0	0.2	0.0	0.0	0.0	0.1	0.0	0.0
Chemical synthesis	0.0	0.0	0.7	0.0	0.0	0.0	0.7	0.1	0.0
Electricity grid	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0	1.0
Interconnection	7.2	16.2	16.2	16.2	16.2	16.2	16.2	16.2	16.2
EV charging stations	0.0	0.3	1.9	1.9	1.9	1.9	1.9	3.8	1.1
Individual heat pumps	1.6	2.3	4.3	4.3	4.3	4.3	4.3	4.3	2.5
Individual biomass boilers	1.0	2.1	2.5	2.5	2.5	2.5	2.5	2.5	2.2
Individual electric heat	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0
Individual oil boilers	2.4	1.2	0.0	0.0	0.0	0.0	0.0	0.0	1.3
Electric cars	0.0	5.4	30.7	30.7	30.7	30.7	30.7	61.3	18.4
Conventional cars	58.1	55.0	34.9	34.9	34.9	34.9	34.9	0.0	48.8
Other vehicles	23.3	24.8	27.7	27.7	27.7	27.7	27.7	27.7	27.7
Total excl. vehicles	28.9	39.1	76.7	69.8	53.2	64.2	69.4	59.8	40.8
Total	110	124	170	163	146	157	163	149	136












NEO

CARBON ENERGY








NEO CARBON ENERGY



2030 SDF Syn






NEO

CARBON ENERGY

#### Recarbonised Finnish Energy System Michael Child► Michael.Child@lut.fi










NEO

CARBON ENERGY

#### Recarbonised Finnish Energy System Michael Child ► Michael.Child@lut.fi



2030 ST






NEO

CARBON ENERGY

#### Recarbonised Finnish Energy System Michael Child ► Michael.Child@lut.fi



2030 SNE






NEO

CARBON ENERGY

#### Recarbonised Finnish Energy System Michael Child ► Michael.Child@lut.fi



2030 SM Syn






Recarbonised Finnish Energy System Michael Child ► Michael.Child@lut.fi



2030 SM EI





NEO

CARBON ENERGY

Recarbonised Finnish Energy System Michael Child ► Michael.Child@lut.fi



2030 BAU 83 Image: NG to Gas Grid [GWh] Import Biogas [GWh] biofuel Biomass Gasifier [GWh] Syngas [GWh] Gasifier Heat [GWh] SNG [GWh] 215 Gas to PtL [GWh] 111 Gas PP [GWh] Transport PtL to Trans [GWh] Oil demands Oil [GWh] Oil CHP [GWh] Oil RES [GWh] Oil Transport [GWh] Gas Export [GWh] V2G Biomass [GWh] 255 104 Biomass Biofuel [GWh] Biofuel Transport [GWh] Electricity Biomass CHP [GWh] demands 206 45 Biomass RES [GWh] 251 Wind [GWh] Biomass Solar PV [GWh] Thermal plants Import [GWh] and heat pumps El to Electrolyzer [GWh] 197 Hydrogen [GWh] 45 El to PtG [GWh] Wind EI to RES [GWh] 140 El to Trans [GWh] Heat El to VtG [GWh] 16 demands VtG to Trans [GWh] PV El to Export [GWh] 249 **RES Heat to heat demand** [GWh] Household IND to EI Demand [GWh] 25 62 IND to Heat Demand [GWh] PP to El Demand [GWh] 142 PP to Heat Demand [GWh] Export or Import 13 Curtailment El to El Demand [GWh] El to PP [GWh] Electricity Import Biofuel [GWh] grid

PtG to Heat demand [GWh]

NEO

CARBON ENERGY





			2020	2050
Renewable energy production		Unit	Value	Value
Wind onshore	Сарех	€/kW <sub>e</sub>	1100	1000
	Lifetime	Years	20	25
	Opex fixed	% of investment	2.5 %	2.5 %
Wind offshore	Сарех	€/kW <sub>e</sub>	2500	2100
	Lifetime	Years	25	25
	Opex fixed	% of investment	2.9 %	3.4 %
Solar PV - ground-mounted	Сарех	€/kW <sub>e</sub>	900	550
	Lifetime	Years	30	35
	Opex fixed	% of investment	2.0 %	1.0 %
Solar PV - rooftop	Сарех	€/kW <sub>e</sub>	1200	700
	Lifetime	Years	30	35
	Opex fixed	% of investment	1.0 %	1.0 %
Biomass gasification plant	Сарех	€/kW <sub>th</sub>	420	320
	Lifetime	Years	25	25
	Opex fixed	% of investment	5.3%	7.0 %
		Efficiency	80 %	80 %
Biodiesel plant	Capex	€/kW <sub>th</sub>	3420	2530
	Lifetime	Years	20	20
	Opex fixed	% of investment	3.0 %	3.0 %
		Efficiency	60 %	60 %
CO <sub>2</sub> Hydrogenation plant (P2G)	Capex	€/kW <sub>th</sub>	1500	600
	Lifetime	Years	20	15
	Opex fixed	% of investment	2.5 %	3.0 %
		Efficiency	60 %	<b>60</b> %
Gasification gas upgrading	Capex	€/kW <sub>th</sub>	300	300
	Lifetime	Years	15	15
	Opex fixed	% of investment	15.8 %	17.6 %



NEO

CARBON ENERGY

55 Recarbonised Finnish Energy System Michael Child ► Michael.Child@lut.fi

CHP plant DH/CHP biomass boiler	Capex Lifetime Opex fixed Variable costs Capex Lifetime Opex fixed Variable costs Capex	Unit €/kW <sub>e</sub> required Years % of investment €/MW <sub>e</sub> required COP €/kW <sub>e</sub> Years % of investment €/MWh <sub>e</sub>	Value 3425 25 2.0 % 0.27 2.9 1200 25 3.75% 2.7	Value 3250 25 2.0 % 0.27 3.0 1200 25 3.75%
CHP plant DH/CHP biomass boiler	Lifetime Opex fixed Variable costs Capex Lifetime Opex fixed Variable costs Capex	Years % of investment €/MW <sub>e</sub> required COP €/kW <sub>e</sub> Years % of investment €/MWh <sub>e</sub>	25 2.0 % 0.27 2.9 1200 25 3.75%	25 2.0 % 0.27 3.0 1200 25
CHP plant DH/CHP biomass boiler	Opex fixed Variable costs Capex Lifetime Opex fixed Variable costs Capex	% of investment €/MW <sub>e</sub> required COP €/kW <sub>e</sub> Years % of investment €/MWh <sub>e</sub>	2.0 % 0.27 2.9 1200 25 3.75%	2.0 % 0.27 3.0 1200 25
CHP plant DH/CHP biomass boiler	Variable costs Capex Lifetime Opex fixed Variable costs Capex	€/MW <sub>e</sub> required COP €/kW <sub>e</sub> Years % of investment €/MWh <sub>e</sub>	0.27 2.9 1200 25 3.75%	0.27 3.0 1200 25
CHP plant DH/CHP biomass boiler	Capex Lifetime Opex fixed Variable costs Capex	COP €/kW <sub>e</sub> Years % of investment €/MWh <sub>e</sub>	2.9 1200 25 3.75%	3.0 1200 25
DH/CHP biomass boiler	Lifetime Opex fixed Variable costs Capex	€/kW <sub>e</sub> Years % of investment €/MWh <sub>e</sub>	1200 25 3.75%	1200 25
DH/CHP biomass boiler	Lifetime Opex fixed Variable costs Capex	Years % of investment €/MWh <sub>e</sub>	25 3.75%	25
DH/CHP biomass boiler	Opex fixed Variable costs Capex	% of investment €/MWh <sub>e</sub>	3.75%	
DH/CHP biomass boiler	Variable costs Capex	€/MWh <sub>e</sub>		3.75%
DH/CHP biomass boiler	Сарех	v	27	
	•	-		2.7
		€/kW <sub>th</sub>	800	800
	Lifetime	Years	20	29
	Opex fixed	% of investment	3.7 %	3.7 %
	Variable costs	€/MWh <sub>th</sub>	0.15	0.15
		Efficiency	90 %	90 %
Condensing power plant	Capex	€/kW <sub>e</sub>	990	980
(average)	Lifetime	Years	27	27
	Opex fixed	% of investment	3.12 %	3.16 %
	Variable costs	€/MWh <sub>e</sub>	2.636	2.636
		Efficiency	45 %	45 %
Individual boiler	Capex	€/unit	5800	5800
	Lifetime	Years	20	20
	Opex fixed	% of investment	2.6 %	2.6 %
		Efficiency	85 %	85 %
Individual heat pump	Capex	€/unit	11500	11500
	Lifetime	Years	20	20
	Opex fixed	% of investment	1.5 %	1.5 %
		COP	3.2	3.7
Individual electric heat	Capex	€/unit	8000	8000
	Lifetime	Years	30	30
	Opex fixed	% of investment	1.0 %	1.0 %
		Efficiency	100 %	100 %



Open your mind. LUT. Lappeenranta University of Te

Recarbonised Finnish Energy System Michael Child ► Michael.Child@lut.fi



Energy storage systems		Unit	2020 Value	2030 Value
Heat storage CHP	Сарех	€/kWh <sub>th</sub>	3	3
	Lifetime	Years	20	20
	Opex fixed	% of investment	0.7 %	0.7 %
Grid gas storage	Сарех	€/kWh <sub>th</sub>	0.081	0.081
	Lifetime	Years	50	50
	Opex fixed	% of investment	1.00 %	1.00 %
Conventional vehicles	Сарех	k€/unit	20.6	20.6
	Lifetime	Years	16	16
	Opex fixed	% of investment	4.1 %	4.1 %
Electric vehicles	Сарех	k€/unit	18.1	18.1
	Lifetime	Years	16	16
	Opex fixed	% of investment	7 %	4.3 %
Motorcycles	Сарех	k€/unit	6	6
	Lifetime	Years	15	15
	Opex fixed	% of investment	5 %	5 %
Trucks	Сарех	k€/unit	99.2	99.2
	Lifetime	Years	6	6
	Opex fixed	% of investment	21.1 %	21.1 %
Buses	Сарех	k€/unit	177.2	177.2
	Lifetime	Years	6	6
	Opex fixed	% of investment	9.14 %	9.14 %
Lithium ion battery (EV)	Capex	€/kWh	200	100
	Lifetime	Years	8	10
	Opex fixed	% of investment	5%	5%



NEO

CARBON ENERGY



		2020	2030
Fuel and CO <sub>2</sub>	Unit	Value	Value
Oil	€/MWh <sub>th</sub>	42.8	47.88
Oil	USD/bbl	107.4	104
Diesel	€/MWh <sub>th</sub>	54.0	61.2
Petrol	€/MWh <sub>th</sub>	54.7	63.36
Jet fuel	€/MWh <sub>th</sub>	58.0	63.36
NG	€/MWh <sub>th</sub>	32.8	36.72
Liquid biofuels	€/MWh <sub>th</sub>	84.8	65.0
Biomass	€/MWh <sub>th</sub>	22.32	24.48
C0 <sub>2</sub>	€/t CO <sub>2 eq</sub>	28.6	34.6





		All years
Fuel handling (storage, distribution and refining)	Unit	Value
Fuel oil to central CHP and PPs	€/MWh <sub>th</sub>	0.943
Fuel oil to industry and DH	€/MWh <sub>th</sub>	6.84
Diesel for transportation	€/MWh <sub>th</sub>	7.56
Petrol / Jet fuel for transportation	€/MWh <sub>th</sub>	7.502
NG to central CHP and PPs	€/MWh <sub>th</sub>	1.476
NG to industry and DH	€/MWh <sub>th</sub>	7.2
Biomass to conversion plants	€/MWh <sub>th</sub>	4.284
Biomass to central CHP and PPs	€/MWh <sub>th</sub>	4.284
Biomass to industry and DH	€/MWh <sub>th</sub>	4.32
Biomass to individual households	€/MWh <sub>th</sub>	10.8
Biomass for transportation (biogas)	€/MWh <sub>th</sub>	4.32





			All years
Infrastructure		Unit	Value
District heating grid	Сарех	€/MWh <sub>th</sub>	72
	Lifetime	Years	40
	Opex fixed	% of investment	1.25 %
District heating substation - Residential	Сарех	€/unit	5500
	Lifetime	Years	20
	Opex fixed	% of investment	2.7 %
District heating substation - Commercial	Сарех	€/unit	21500
	Lifetime	Years	20
	Opex fixed	% of investment	5.00 %





Parameter	Unit	2020	2030	2030 BAU
Number of DH customers	Thousand	0.95	1.2	1.1
Total heat production	(GWh <sub>th</sub> )	130	150	140
Grid costs	(€/MWh <sub>th</sub> )	72	72	72
Total grid costs	(k€)	9360	10800	10080
Number of residential customers	Thousand	0.54	0.6	0.66
Cost of residential substation	(€/unit)	5500	5500	5500
Number of commercial customers	Thousand	0.41	0.6	0.44
Cost of commercial substation	(€/unit)	21500	21500	21500
Total substation costs	(k€)	11785	16200	13090
Substation opex	(k€)	589	810	654





		All years
Carbon content in fuels	Unit	Value
Oil	kg CO <sub>2eq</sub> /MWh <sub>th</sub>	266.4
NG	kg CO <sub>2eq</sub> /MWh <sub>th</sub>	204.12
Solid biomass	kg CO <sub>2eq</sub> /MWh <sub>th</sub>	396

